

Energy Performance Certificate

Non-Domestic Building



FIRST FLOOR - FRONT
35 Piccadilly
LONDON
W1J 0DN

Certificate Reference Number:
0930-3938-0353-3053-9040

This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information in the guidance document *Energy Performance Certificates for the construction, sale and let of non-dwellings* available on the Government's website at www.gov.uk/government/collections/energy-performance-certificates.

Energy Performance Asset Rating

More energy efficient

A+

Net zero CO₂ emissions

A 0-25

B 26-50

C 51-75

D 76-100

E 101-125

F 126-150

G Over 150

Less energy efficient

◀ 94

This is how energy efficient the building is.

Technical Information

Main heating fuel:	Oil
Building environment:	Heating and Natural Ventilation
Total useful floor area (m ²):	106
Building complexity (NOS level):	3
Building emission rate (kgCO ₂ /m ² per year):	69.63
Primary energy use (kWh/m ² per year):	327.23

Benchmarks

Buildings similar to this one could have ratings as follows:

25

If newly built

73

If typical of the existing stock